



PART NUMBER		TAB SIZE	WIRE RANGE AWG (mm <sup>2</sup> )	DIMENSIONS in		
PREFIX	PKG			A $\pm 0.03$ (0.8)	B $\pm 0.01$ (0.3)	C $\pm 0.01$ (0.3)
D18-188B	-C	.187 x .020	22-18	.56	.23	.10
	-M	(4.8 x 0.5)	(.5-1.0)	(14.2)	(5.8)	(2.5)
D14-188B	-C	.187 x .020	16-14	.56	.23	.10
	-M	(4.8 x 0.5)	(1.5-2.5)	(14.2)	(5.8)	(2.5)



NOTES:

- USED FOR:  
A. STRANDED COPPER WIRE ONLY  
B. 302°F (150°C) MAX TEMP RATING
- PACKAGE QTY:  
A. STD: C=100  
B. BULK: M=1000
- MATERIAL:  
A. STAMPING: .016 (0.41) THK BRASS, TIN PLATED
- WIRE STRIP LENGTH  $9/32 \begin{matrix} +1/32 \\ -0 \end{matrix}$  (7.1  $\begin{matrix} +0.8 \\ -0 \end{matrix}$ )
- FIRST INSERTION FORCE: 12 LB (53N) MAX  
FIRST WITHDRAWAL FORCE: 12 LB (53N) MAX  
6 LB (27N) MIN
- INSTALLATION TOOLS:  
A. CT-100 (POCKET B)
- DIMENSIONS IN BRACKETS ARE IN MILLIMETERS OR mm<sup>2</sup>



CERTIFIED  
LR31212

A41303\_06

06	7/03	KLFU		ADDED INTERNAL SERRATIONS WIRE RANGE .5 WAS .38						
05	1/01	RM	SKB	FILESPEC WAS N41303AA_PCD_04	8933		JAC	CCH		
04	4/95	MS		REMOVED SLOT FROM TERMINAL	03131					
03	10/94	TH	RS	UPDATED NOTES AND DIMENSIONS	02549		LA	TFK		
REV	DATE	BY	CHK	DESCRIPTION	ECN #	QA	CUST	PM	APP	

**PANDUIT**

CORP.

TINLEY PARK, ILLINOIS

NON-INSULATED FEMALE DISCONNECT,  
BUTTED SEAM (.188 SERIES)

DRAWN BY

DAW

CHK'D

SCALE

NONE

DRAWING NO.

A41303